

Inspection Chart for installing HyDra RX 101



Project	Contractor	Responsible	
Inspected by	Place		
Inspection points		Control by installer	Control by forman
Before installation, remove loose stones and concrete residue			
The surface must be cleaned of concrete slurry, ice, binding wire etc.			
The waterstop must not come into contact with moisture or water before casting.			
The waterstop is to be placed centrally in the joint, unless otherwise prescribed.			
The cover must be min. 80 mm. IMPORTANT			
The waterstop be in contact with the base, use a net for mounting.			
The net must be fixed properly, as it must not come loose during casting.			
The crossing point, corners and edges must butt, no overlaps.			
Waterstops that have started to expand must be replaced with new ones.			
The concrete surface where the waterstop is mounted must be moistened with water before casting.			
The waterstop must be casted in carefully.			
Do not expect immediate sealing. The waterstop expands slowly			
Remarks		Application date	Casting date
		Weather conditions	Temperature
Inspected and approved by	Date	Ref. Drawing number	

If you have any questions, please contact us at +45 8622 9393