

Inspection chart for installing WaterproofX 100

Project and case number

Contractor

Responsible installer

Inspected by

Construction part

Montørens egenkontrol

Formandens kontrol

Clean surface

No sharp objects

Dry or damp surface

Holes and unevenness must be filled with HyDra Swelling Paste SX 100

Fixing clamps c/c distance of 100-150 mm in the entire length of the injection hose including corners

The entire hose must continually be attached to the surface

Concrete cover min. 100 mm

30 meter max length of injection hose

At hose section joints the hoses must overlap by 150 mm and lie parallel at a distance of 30-50 mm

Control that the hose and Varioclix have been installed correct

Damaged injection hose must be replaced

Remarks

Application date

Casting date

Weather conditions

Temperature

Inspected and approved by

Date

Ref. Drawing number

If you have any questions, please contact us at +45 8622 9393